

RADNOR TOWNSHIP

APPLICATION FOR SEWER CONNECTION

**301 IVEN AVENUE
WAYNE, PA 19087-5297
610-688-5600**

DATE: _____/_____/_____

APPLICANT NAME: _____

APPLICANT ADDRESS: _____

Applicant hereby applies for Permit to connect property at:

LOCATION: _____

TYPE: ___ RESIDENTIAL ___ COMMERCIAL ___ MULTI FAMILY

OWNED BY: _____

Whose consent has been obtained to connect to the Sanitary Sewer

CONTRACTOR NAME: _____

ADDRESS: _____

PHONE NO: _____ WORK TO START: _____/_____/_____

CONTRACTOR LICENSE NO: _____

The filing of this application constitutes an agreement that the applicant will comply with the terms and conditions set forth in the Township ordinances and regulations pertaining to the work involved.

All sanitary sewer laterals are required to be Schedule 40 or SDR 35

All plastic pipe shall be laid in SIX (6) inches of stone and with 6-inches of stone coverage.

A two way clean out shall be installed within five (5) feet of the road edge or sewer.

PER: _____ DATE: _____/_____/_____

TITLE: _____

TOWNSHIP USE ONLY

PERMIT NO: _____ RECEIPT NO: _____ FEE: _____

RADNOR TOWNSHIP SEWER CONNECTION REGULATIONS

PLEASE CALL 610-688-5600 TO SCHEDULE AN INSPECTION

72 Hour Notice Required

Inspectors:

Andy Pancoast- Code Official (from house to the sewer main) - Ext 140
Tom Kennedy- Code Inspector (from house to the sewer main) -Ext 169
Mike Bozzuto - Code Inspector (from house to the sewer main) - Ext 169
Matt Pillotti - Sewer Department Supervisor (from trap to main) -Ext 196
Matt Pillotti- Highway Department Supervisor (roadway inspections) -Ext 196

Laterals:

1. All plastic pipe must be laid in six (6) inches of 2B stone.
2. A test shall be performed and inspected by the Code Official.
3. All plastic pipe must be covered with six (6) inches of 2B stone.
4. All sanitary sewer laterals must be in a straight line from right of way to main.

Backfill & Restoration of Yard:

1. All plastic pipe must be covered with six (6) inches of 2B stone.
2. After a section of sewer is built, the trench shall be backfilled with acceptable material in layers not more than one (1) foot in depth. Each layer shall be thoroughly compacted to the required elevation. All backfilling shall be done under the supervision of a Township Inspector.

Backfilling & Final Restoration with the Paved Roadway:

1. A road opening permit is required before any excavation is begun on Township Roadways. This can be obtained from the Engineering Department (610-688-5600 x 130 or 133)
2. All backfilling shall be done under the supervision of a Highway Department Supervisor.
3. When backfilling, 2RC shall be used and tamped in one (1) foot lifts until seven (7) inches below grade. The trench is then to be filled with five (5) inches of BCBC (black base) compacted property, followed by two (2) inches of ID 2 top rolled to the height of the existing wearing course. The seams are then to be sealed with AC 20 or equivalent to completed final restoration;

**FAILURE TO NOTIFY THE ABOVE INSPECTORS WILL RESULT IN COMPLETE
OPENING OF THE TRENCH**